



| | |
|------------------|-------------|
| Model # | CBK |
| Serial # | |
| Kilowatts | 36.00 |
| Volts/Ph/Hz | 460 / 3/ 60 |
| Control Volts | 24 |
| Steps | 2 |
| Heater Amps | 43.3 |
| Heater Fuses | N/A |
| System Amps. | N/A |
| V.A. | 21.0 |
| Min. F.P.M. | 1150 |
| Min. Wire Ga. CU | # 6 AWG |
| Control Wiring | --- |
| Power Wiring | --- |
| Other Wiring | --- |

NOTE :

- *Replace one shot therm-D-disc with L300F-61F14/L300F-60FXX14, use copper wire only suitable for at least 75°C.
- ** Replace auto-reset with thermo disc type 60TX11-L145
- ***Replace manual-reset with thermo disc type 60TX11-L175

-FIELD WRING,NEC Class I.

WARREN TECHNOLOGY

| | |
|------------------|---|
| Aprv. by DJG | RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram |
| Rev. by B.NGHIEM | MODEL EC1 36 KW 480/3 |
| Date : 12/30/03 | Dwg: RUP\EC\WEC1RP3605 |